



ADHUNIK POWER & NATURAL RESOURCES LIMITED

WORKS : Village - Padampur, Behind P.G.C.I.L. Substation,
Adityapur - Kandra Road, Saraikela - Kharsawan, PIN - 832402 Jharkhand
Phone : +91 - 657 - 6628400, Fax : +91 - 657 - 6628440
CIN - U40101WB2005PLC102935

Ref No APNRL/JSPCB/ES/2020-21/02

Date: 20th Sep 2021

Member Secretary
Jharkhand State Pollution Control Board,
HEC Campus, Dhurva,
Ranchi, Jharkhand.

Sub- Submission of Environmental Statement (Form V) for Unit II (1 x 270 MW) of M/s
Adhunik Power & Natural Resources Limited, Village- Padampur, Dist- Saraikela-
Kharswan, Jharkhand.

Ref: Environmental Clearance letter No J-13012/8/2009-IA.II(T), Dated 09th May 2011.

Dear Sir,

In line with compliance of above referred EC letter point No XIII of general condition, Please
find attached herewith Environmental statement (Form V) for the financial year 2020-21.

This is for your kind information & record please.

Thanking You

Yours faithfully

Kamlesh Kumar

Manager (Environment)

Encl: As mentioned above

CC: 1. Regional Office (ECZ),

Ministry of Environment, Forest and Climate Change,
Bungalow No. A-2, Shyamali Colony, Ranchi - 834002

2. Regional Officer

Jharkhand Pollution Control Board

Jamshedpur, Jharkhand




CORPORATE OFFICE : "LANSLOWNE TOWER", 2/1A, Sarat Bose Road, Kolkata - 700 020
Ph : +91 - 33 - 30517100 / 7200 / 7300 • Fax : +91 - 33 - 22890285

REGD. OFFICE

: 14, N. S. Road, 2nd Floor, Kolkata - 700 001, Phone No. +91 - 33 - 22428551, 22428553

Website

: www.adhunikpower.com



ENVIRONMENTAL STATEMENT

For

1 X 270 MW COAL BASED THERMAL POWER PLANT

(UNIT II)

FINANCIAL YEAR 2020-21



September 2021



Adhunik Power & Natural Resources Ltd
Village-Padampur, District-Saraikela-Kharsawan
Jharkhand-832402

FORM-V

From:

Adhunik Power & Natural Resources Limited

Village: Padampur

Dist: Saraikela-Kharsawan – 832 402

Jharkhand.

To,

Member Secretary

Jharkhand State Pollution Control Board,

HEC Campus, Dhurva,

Ranchi, Jharkhand.

Environmental Audit Statement for the financial year ending on the 31st March-2021 for
Unit-II (1 x 270 MW)

PART – A

- | | | |
|---|---|--|
| (i) Name & Address of the owner/occupier of the Industry operation or process | : | Sh. Raghvendra Kumar Singh
Adhunik Power & Natural Resources
Ltd, Vill- Padampur, Adityapur-
Kandra Road, Dist- Sariekela-
Kharswan, Jharkhand |
| (ii) Industry Category | : | Red Category |
| (iii) Production Capacity – (Units-MW) | : | Power
270 MW Per Hour |
| (iv) Year of Establishment
(COMMERCIAL PRODUCTION DECLARED) | : | 19 th May 2013 |
| (v) Date of Last Environmental Statement
Submitted | : | 25 th September 2020 |

PART-B

Water and Raw Material Consumption

(i) Water Consumption KL/Day

Process : 1921.3

Cooling : 10576.0

Domestic : 61.3

Name of product	Process water consumption per unit of product output	
	During the previous financial year 2019-20	During the current financial year 2020-21
Electricity 270 MW Per Hour	0.363 KL	0.350 KI

(ii) Raw Material Consumption

Name of Raw Materials	Name of product	Consumption of raw material per unit of output (Total Production)	
		During the previous financial year 2019-20	During the current financial year 2020-21
Coal	Power	0.713 MT	0.667 MT
LDO		0.00045 KL	0.00019 KL

PART – C

Pollution Discharged to environment / unit of output.
(Parameter as specified in the consent issued)

Pollutants	Qty. Of pollutants discharged (Mass / Day)	Concentration of Pollutants in discharges (Mass / Day)	Percentage of variation from prescribed standards with reasons
(i) Water Unit Limit pH 5.5. to 9.0 SS < 100 mg/l Oil & Grease < 10 mg/l BOD ₅ < 30 mg/l COD < 250 mg/l	1) Effluent generated from Cooling tower, DM plant, IBD tank, CPI separator is being utilized in HCDL system. 2) Effluent generated from CBD is being reutilized in quenching & dust suppression system. 3) Effluent generated from STP is being utilized for gardening		Concentration are below the prescribed limits. ETP & STP analysis report are enclosed as Annexure I
(ii) Air PM SO ₂ NO _x		26 mg/Nm ³ 1393.65 mg/Nm ³ 362.9 mg/Nm ³	Concentration are below the prescribed limits. Stack monitoring report are enclosed as Annexure II

*The Effluent Treatment facility for Unit I and Unit II is common.

PART - D
HAZARDOUS WASTES

(As specified under Hazardous Wastes Management and Handling
& Transboundary Movement Rules, 2008)

Hazardous Wastes	Total Quantity (KL).	
	During the previous financial Year 2019-2020	During the current financial Year 2020-2021
1 From Process	Used Oil-1.436 KI Waste Oil-1.270 KI	Used Oil- 3.5428 KI Waste Oil- 1.1704 KI
2 From Pollution Control Facilities	0 KL	0 KL

- The APNRL has obtained Hazardous Waste Authorization from JSPCB for Collection & Storage of Hazardous waste.
- Waste / Spent Oil is collected at centrally located point in isolated stores area meant for them in sealed M.S. Drums which is further sent to authorized recycler for disposal as per norms of MoEF.

PART -E

Solid Wastes

	Total Quantity (MT)	
	During the previous financial Year 2019-2020	During the current financial Year 2020-2021
(a) From Process • Bottom Ash	67874.89 MT	73043 MT
(b) From Pollution Control Facility • Fly ash	384624.40 MT	413913 MT
(c) (1) Quantity recycled or re-utilized within the unit		
(2) Sold		
(3) Disposed • Fly Ash • Bottom Ash	384624.40 MT 67874.89 MT	413913 MT 73043 MT

PART – F

Please specify the characterization (In terms of composition and quantum) of hazardous as well as solid and indicate disposal practice adopted for both these categories of wastes.

Hazardous Waste:

1) Solid Hazardous Waste:

- Bio medical Waste is generated from OHC is being disposed as per CPCB Guidelines.
- Waste generated from Canteen is used from preparing bio-compost & it is used for plantation.
- For the collection of dry fly ash, silos have been provided with pneumatic system & Bottom ash is led to the Ash dyke through pipeline in wet slurry mode.

2) Liquid Hazardous waste:

- In this financial year, 3.5428 KL (Used Oil) & 1.1704 KL Waste Oil have been generated from process and disposed to authorized recycler as per norms of MoEF.

PART - G

Impact of the pollution abatement measures taken on conservation of natural resources and on the production.

The following practices are adopted for the pollution control & conservation of natural resources:

- We are using effluent water generated from Cooling tower, DM plant, IBD tank for Ash handling system instead of fresh water from River Subarnarekha.
- Extensive tree plantation is under progress as a part of green belt development, which will control the impact of Air pollution and optimize the ambient temperature of surrounding areas.
- Twin flue stack with height of 275 m are provided as per the CPCB guidelines for better dispersion of emissions and keep the concentrations within JSPCB/CPCB specified standards.
- High efficiency Electrostatic precipitators (ESPs) are provided for control of dust emissions into flue gases.
- Dust suppression system is installed at Truck tipping area.
- Dust Extraction system along with bag Filters have been installed at Coal Silo, Coal bunker, Intermediate Silo & Ash Silo to arrest the fugitive emissions.
- Roof sheeting and side cladding in conveyor galleries and TPs are installed to control fugitive dust

- The plant is designed on COC of more than 5 which is helpful in water conservation which further lead to reduction in overall fresh water intake.
 - Garland drain connected with coal settling pit are installed in the Coal Stockyards for the reutilize of coal containing water.
 - Mist canyons are installed around the coal stock yard for the control of fugitive dust.
 - Belt washing system, coal settling pits and waste water recovery system are installed at transfer house for the dust suppression and water recovery.
 - Water spraying system is installed in ash pond area for controlling the ash fugitive emissions, if any.
 - Low NOx burners are installed in fuel combustion system for controlling NOx emissions
 - Effluent Treatment Plant (ETP) and Sewage Treatment Plants (STP) are installed to control water pollution.
 - Rain Water harvesting is being practiced in the plant premises, which helps in ground water recharging.
 - Good housekeeping is maintained within the plant premises.
 - Green belt has been developed in & around the plant periphery to control the dispersal of dust particles and attenuate the noise generated during the process.
- Because of the adaptation of aforementioned methods, the quality of emissions and discharges are maintained below the permissible limits prescribed by the MoEF&CC / CPCB / JSPCB.

PART - H

Additional measures / investment proposals for environmental protection including abatement of prevention of pollution.

APNRL is regularly monitoring ambient air, stack, noise level, water quality and soil quality in and around the plant premises. All the emissions and discharges are meeting the permissible limits prescribed by MoEF / CPCB / JSPCB. It is proposed to further strengthen the monitoring and reporting process. Ash Water Recovery System is installed for further reuse of ash water. Green belt development within plant premises is proposed to be accelerated.

PART – I


Any other particulars for improving the quality of the environment:

The part – I of any Environmental Statement report is perhaps the best scale to measure various parameters of the plans, target, achievements and ultimate impact. APNRL has made sincere efforts to visualize the general environmental scenario and implemented plan for the associated improvements. Some highlights are mentioned below:

1. Received certification for ISO 9001:2008, ISO 14001: 2004 & ISO 18001:2007 from BSI.
2. Training on EMS to all employees and contract labors to create Environment awareness.

3. Green Belt development is under progress.
4. Only PUC certified vehicles are engaged.
5. Monitoring of Ambient air quality, Surface and ground water quality, stack monitoring, soil, Noise level is being done through MoEF & NABL accredited laboratory.
6. Full-fledged Environmental laboratory has been installed.
7. Installation of Online Effluent monitoring system has been completed.
8. Webhosting of online environment data on CPCB/SPCB website have been completed.
9. Electronics Display board is provided at the main gate for public data display.
10. Audit by recognized organization i.e. ERM has been conducted to improve Environmental & Social Management system (EMS).
11. Celebration of Environmental promotional activities (Environment day, Earth Day, Water day, Ozone day).
12. Remote calibration facility of CEMS has been completed.
13. 200 no Solar light system has been installed in plant premises.

Date: 20/09/2021

Signature : 
Name : Kamlesh Kumar
Designation : Manager- Environment
Address : Adhunik Power & Natural Resources
Limited, Village : Padampur
Dist: Saraikela-Kharsawan –
832 402. Jharkhand



YUGANTAR BHARATI

ANALYTICAL & ENVIRONMENTAL ENGINEERING LABORATORY

Accredited by: - National Accreditation Board for Testing Laboratory (NABL) & Jharkhand State Pollution Control Board (JSPCB)
 Certified by: - An ISO 9001:2015 & BS OHSAS 18001 : 2007



Certificate No. - TC 7813

ANALYTICAL TEST REPORT

Water Test Report		URL (Unique Lab Report) No.		TC78132130000028P	
Date of Issue	28 th March 2021	Report ID		YBAEEL-210308 -122658 -WW01	
Sample Description	Waste Water	Job code / Ref. no.		YBAEEL/WA/L/C/Mar.-21/09	
Type of Industries	Thermal Power Plant	Work Order No./ Date		3030005309 - 27/02/2021	
Issued to: -	M/s Adhunik Power & Natural Resources Limited Vill.- Padampur, Behind PGCIL Sub-station, Jamshedpur-832402, Jharkhand.				
Sampling date	18/03/2021	Mode of sample Collection		By YBAEEL Team	
Sampling Protocol	IS : 3025 (Part-1) 1987, R-2003	Sample Code		210318 - WW - E01	
Sampling Location	Final Outlet of ETP	Sampling Source		Effluent Water	
Sample pkg. Condition	Sealed Pack in PP Bottle	Sample Quantity		3000 ml	
Meteorological cond.	W.C. - Clear	RH - 39 %		Temp. - 29°C	
Work allotted date	18/03/2021	Test started on	18/03/2021	Test completed on	26/03/2021

Test Result					
Sl	Parameter	Test Method	Units	Results	Limits
1.	pH value	IS 3025 (P-11):2002	pH	7.85	5.5 -9.0
2.	Temperature	IS 3025 (P-09)	°C	27.2	40
3.	Total suspended solids	IS 3025 (P-17):2012	mg/l	38.0	100
4.	Chloride (as Cl ⁻)	IS 3025 (P-32):2003	mg/l	11.6	1000
5.	BOD	IS 3025 (P-44):2009	mg/l	18.0	30
6.	COD	IS 3025 (P-58):2006	mg/l	100.0	250
7.	Chromium (as Cr)	APHA 3111 B 23 rd edition 2017	mg/l	ND (DL 0.02)	--
8.	Copper (as Cu)	APHA 3111 B 23 rd edition 2017	mg/l	0.03	3
9.	Lead (as Pb)	APHA 3111 B 23 rd edition 2017	mg/l	0.03	0.1
10.	Zinc (as Zn)	APHA 3111 B 23 rd edition 2017	mg/l	ND (DL 0.1)	5
11.	Sulphate (as SO ₄ ²⁻)	IS 3025 (P-24):2003	mg/l	9.4	1000

*****End of Test*****

Remarks :- Samples Comply with the prescribed Specification as per IS:2490:1974

Note :- The parameters marked with * are not accredited by NABL.

Specific contractual notes: -

- ◆ The results listed refer only to the tested sample and applicable parameter.
- ◆ This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- ◆ This report cannot be reproduced, except when in full, without the written permission of the Lab In-charge
- ◆ The samples received shall be destroyed after two month from the date of issue of the certificate unless specified otherwise and sample for biological testing will be destroyed after one two week of testing.
- ◆ The liability of the laboratory is limited to the invoiced amount.
- ◆ All disputes are subjected to the Ranchi Jurisdiction.
- ◆ ND - not detected, DL - detectable limit

 Tested by Prem Kumar Lab Analyst	 Checked by Brij Nandan Kumar In-Charge Pollution & Environment	 Issued by Umesh Das Technical Manager
	Authorized Signatory Pollution & Environment	
	Yugantar Bharati Analytical & Environmental Engineering Laboratory	

Page 1 of 1



Branch Office :- Jamshedpur

Dhanbad

Envi Hazaribag

Pakur

Main Office : Namkum Post Office, Sidroul, Ranchi - 834010, Jharkhand
 Ph : 098351-97960, 098357-86677, Email - ybaeel@gmail.com, Web - https://ybaeel.in



TÜV Rheinland®
 ISO 9001:2015
 BS OHSAS 18001:2007



YUGANTAR BHARATI

ANALYTICAL & ENVIRONMENTAL ENGINEERING LABORATORY



Accredited by :- National Accreditation Board for Testing Laboratory (NABL) & Jharkhand State Pollution Control Board (JSPCB)
Certified by :- An ISO 9001:2015 & BS OHSAS 18001 : 2007

Certificate No. - TC 7813

ANALYTICAL TEST REPORT

Water Test Report

Water Test Report		URL (Unique Lab Report) No.	TC78132130000029P
Date of Issue	28 th March 2021	Report ID	YBAEEL-210308 -122658 -WW02
Sample Description	Waste Water	Job code / Ref. no.	YBAEEL/WA/L/C/Mar.-21/10
Type of Industries	Thermal Power Plant	Work Order No./ Date	3030005309 - 27/02/2021
Issued to : -	M/s Adhunik Power & Natural Resources Limited Vill.- Padampur, Behind PGCIL Sub-station, Jamshedpur-832402, Jharkhand.		

Sampling date	18/03/2021	Mode of sample Collection	By YBAEEL Team		
Sampling Protocol	IS : 3025 (Part-1) 1987, R-2003	Sample Code	210318 – WW – E02		
Sampling Location	Final Outlet of STP	Sampling Source	Sewage water		
Sample pkg. Condition	Sealed Pack in PP Bottle	Sample Quantity	3000 ml		
Meteorological cond.	W.C. – Clear	RH – 39 %	Temp. – 29°C		
Work allotted date	18/03/2021	Test started on	18/03/2021	Test completed on	26/03/2021

Test Result

Sl	Parameter	Test Method	Units	Results	Limits
1.	pH value	IS 3025 (P-11):2002	pH	7.59	5.5-9.0
2.	Temperature*	IS 3025 (P-09)	°C	26.9	40
3.	Total suspended solids	IS 3025 (P-17):2012	mg/l	48.0	100
4.	BOD	IS 3025 (P-44):2009	mg/l	22.0	30
5.	Oil and grease	IS 3025 (P-39):2003	mg/l	2.4	10
6.	Chloride	IS 3025 (P-32):2003	mg/l	31.8	1000

*****End of Test*****

Remarks :- Samples Comply with the prescribed Specification as per IS:2490:1974.

Note :- The parameters marked with * are not accredited by NABL.

Specific contractual notes :-

- ♦ The results listed refer only to the tested sample and applicable parameter.
- ♦ This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- ♦ This report cannot be reproduced, except when in full, without the written permission of the Lab In-charge.
- ♦ The samples received shall be destroyed after two month from the date of issue of the certificate unless specified otherwise and sample for biological testing will be destroyed after one two week of testing.
- ♦ The liability of the laboratory is limited to the invoiced amount.
- ♦ All disputes are subjected to the Ranchi Jurisdiction.
- ♦ ND - not detected, DL - detectable limit

Tested by Prem Kumar Lab Analyst		Checked by Brij Nandan Kumar In-Charge Pollution & Environment	Authorized Signatory Umesh Das Pollution & Environment Technical Manager Yugantar Bharati Analytical & Environmental Engineering Laboratory
Issued by		Page 1 of 1	



Branch Office :- Jamshedpur

Dhanbad

Hazaribag

Pakur

Main Office : Namkum Post Office, Sidroul, Ranchi - 834010, Jharkhand
Ph : 098351-97960, 098357-86677, Email - ybaeel@gmail.com, Web - https://ybaeel.in



TÜV Rheinland
ISO 9001:2015
BS OHSAS 18001:2007



Test Report



TC-6721

Print Date : 22/09/2020

SAMPLE DRAWN BY SGS INDIA PVT. LTD.

Report No : JE20-000336.002

JOE No : JE20-000336

ULR No : TC672120000002991P

Report Control No : JER0000020547

Sample Described by Customer as : FLUE_GAS

Client Name : ADHUNIK POWER AND NATURAL RESOURCES LIMITED
Client Address : VILL-PADAMPUR, BEHIND PGCIL
: ARAIKELA-KHARSWAN
Postal Code : 832402
State : Jharkhand
Country : INDIA
Sample Type : FLUE_GAS
Received : 18/09/2020
Marks on Sample : Stack Boiler - 2
Sample : 15.09.2020, time- 03.00 pm to 04.20 pm
Collection Date :
Emission Due to : Burning of Coal
Height of Stack : 275.0 mt.
from Ground
Level
Height of : 90.0 mt
Sampling Point
from GL
Diameter of Stack : 4.2 mt
at Sampling Point
Type of Stack : Circular
Platform & : Yes
Ladder at Stack
Capacity : 270 M.W/hr.
Running Load : 196 M.W/hr.
Fuel : 146 TPH
Consumption
Fuel Used : Coal
Pollution Control : ESP
Device
Construction : RCC
Material of Stack
Sampling Method : SO-IN-MUL-TE-176
Test Start/End Date : 18/09/2020 - 22/09/2020

NABL Accredited Tests

Analysis	Method	Result	Unit
NABL Group :	Atmospheric Pollution	Stack emission	
Oxygen (O2)	USEPA 3A	6.4	%
Sulphur Dioxide (SO2)	IS:11255 (Part-2):1985 (Reaff:2014)	1393.65	mg/Nm3

Page 1 of 4

This document is issued by the Company under its General Conditions of Service printed overleaf or available on request and accessible at http://www.sgs.com/terms_and_conditions.htm and Terms and Conditions for electronic documents www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 7 days (in case of perishable items) and 30 days for all other samples from the date of issue of report. The samples from regulatory bodies are to be retained as specified. This document cannot be reproduced except in full, without prior written approval of the Company.

For any feedback or complaint please write to us at feedback.mlgurgaon@sgs.com.

SGS India Pvt. Ltd. | 152, New Baradwan Layout Extension, Sakchi, Jamshedpur - 831 001, Jharkhand Contact no : 6572422919 www.sgs.com

Member of the SGS Group (SGS SA)

SAMPLE DRAWN BY SGS INDIA PVT. LTD.

Report No : JE20-000336.002

JOE No : JE20-000336

ULR No : TC672120000002991P

Report Control No : JER0000020547

NABL Accredited Tests

Analysis	Method	Result	Unit
NABL Group : Atmospheric Pollution Stack emission			
Oxides of Nitrogen as NO2	IS 11255 (Part 07) : 2014	362.9	mg/Nm3
DISCIPLINE: CHEMICAL			
Particulate Matter (PM)	IS 11255 (Part 1) -1995 Reaff-2014	26	mg/Nm3

Page 2 of 4

This document is issued by the Company under its General Conditions of Service printed overleaf or available on request and accessible at http://www.sgs.com/terms_and_conditions.htm and Terms and Conditions for electronic documents www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 7 days (in case of perishable items) and 30 days for all other samples from the date of issue of report. The samples from regulatory bodies are to be retained as specified. This document cannot be reproduced except in full, without prior written approval of the Company.

For any feedback or complaint please write to us at feedback.mlgurgaon@sgs.com.



Test Report

Print Date : 22/09/2020

SAMPLE DRAWN BY SGS INDIA PVT. LTD.

Report No : JE20-000336.002

JOE No : JE20-000336

ULR No : TC672120000002991P

Report Control No : JER0000020547

Non-Accredited tests

Analysis	Method	Result	Unit
NABL Group : Atmospheric Pollution Stack emission			
Moisture	IS 11255 Part 3:1985 (Reaff.2003)	9.2	%
Temperature	IS 11255 Part 3:1985 (Reaff.2003)	111	°C
Barometric Pressure	IS 11255 Part 3:1985 (Reaff.2003)	731	mm Hg
Velocity	IS 11255 Part 3:1985 (Reaff.2003)	21.99	m/s
Quantity of Gas Flow	IS 11255 Part 3:1985 (Reaff.2003)	739522	Nm3/Hrs
Carbon Monoxide (CO)	USEPA 10B	5	mg/Nm3
Carbon Dioxide (CO2)	USEPA 3A	12.8	%

Page 3 of 4

This document is issued by the Company under its General Conditions of Service printed overleaf or available on request and accessible at http://www.sgs.com/terms_and_conditions.htm and Terms and Conditions for electronic documents www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 7 days (in case of perishable items) and 30 days for all other samples from the date of issue of report. The samples from regulatory bodies are to be retained as specified. This document cannot be reproduced except in full, without prior written approval of the Company.

For any feedback or complaint please write to us at feedback.mlgurgaon@sgs.com.

SGS India Pvt. Ltd. | 152, New Baradwan Layout Extension, Sakchi, Jamshedpur - 831 001, Jharkhand Contact no : 6572422919 www.sgs.com

Member of the SGS Group (SGS SA)



Test Report

Print Date : 22/09/2020

SAMPLE DRAWN BY SGS INDIA PVT. LTD.

Report No : JE20-000336.002

JOE No : JE20-000336

ULR No : TC672120000002991P

Report Control No : JER0000020547

Remark : Instrument No- 02A17

Per pro SGS India Private Ltd

Manish Kumar

Chemist

Authorized Signatory

****End of Report****

Page 4 of 4

This document is issued by the Company under its General Conditions of Service printed overleaf or available on request and accessible at http://www.sgs.com/terms_and_conditions.htm and Terms and Conditions for electronic documents www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 7 days (in case of perishable items) and 30 days for all other samples from the date of issue of report. The samples from regulatory bodies are to be retained as specified. This document cannot be reproduced except in full, without prior written approval of the Company.

For any feedback or complaint please write to us at feedback.mlgurgaon@sgs.com.